

# Amendments to Invitation to Supply Potable Water to the Water Corporation of Anguilla

---

The following are amendments and specifics with direct reference to the initial document entitled, "Invitation to Supply Potable Water to The Water Corporation of Anguilla." The amendments are as follows:

- 2.1.1. The unit 'gallons per day' refers more specifically to US gallons per day.
- 2.1.2. A turnaround time should be specified in each tender as to a time for first production of water at a rate of 500,000 US GPD. This rate should be able to increase up to 1,000,000 US GPD within three (3) months of official written request, and agreement, by the WCA.
- 2.2.1. The product water shall comply with the requirements of the World Health Organisation (WHO) Fourth Edition of the guidelines for drinking-water quality.
- 2.4.1. The WCA will ensure that all pipes leading from the plant to the potable water storage tank are functional. After an agreement has been reached that conditions are acceptable, all maintenance is the responsibility of the company possessing the winning bid.
- 5.1. All companies should be mindful that a buyout schedule should be included in your proposal.
- 5.3. The WCA is responsible for payment of all energy cost subject to the conditions that it does not exceed the rate range stipulated in section 5.4. If the maximum rate is exceeded the difference will be paid to the WCA by the company possessing the successful tender. If the energy costs fall below the minimum

rate, all savings shall be split 50/50 between the WCA and the company possessing the successful tender.

5.4. The proposal shall guarantee an energy consumption (kWh) per 1000 US gallon supplied rate falling between 17 and 19 inclusive.

5.6.3. The quality of the water product delivered to the WCA potable water storage tank shall correspond with the WHO fourth edition guidelines for drinking-water quality.

5.6.4. Recovery of product water from the plant shall be 40% - 45% or greater from the fee water supplied.

5.6.9. Preference will be given to companies to companies that make provisions for alternative energy sources to be utilized; turbines, solar etc.

5.6.10. No containers or equipment shall be stored outside of the storage building, unless agreed upon by the WCA.

8.2.3. Tenders shall be received by the WCA not later than 1200 hours local Anguillan time on Monday June 30, 2014.

8.3.1. Tenders shall be opened by the WCA board of directors in public on Wednesday July 2, 2014.

8.4.1. The preferred tender shall be the one that submits the lowest cost with maximum efficiency, that is the technically compliant tender and that satisfies the criteria in relation unit rates and previous experience for this type of agreement.