Revised Regulations of Anguilla: P40-2

PETROLEUM ACT (R.S.A. c. P40)

ERECTION AND CONSTRUCTION OF PUMPS FOR PETROLEUM STORAGE REGULATIONS

Note: These Regulations are enabled under section 16 of the Petroleum Act, R.S.A. c. P40.

Pumps to be licensed

1. No pump shall be used for the storage of petroleum unless such pump is licensed in accordance with these Regulations by the Comptroller of Inland Revenue.

(Act 6/2010, s. 41)

Licensing of pumps

2. No fixed pump shall be licensed unless—

(a) the position of such pump shall have been approved by the Commissioner of Police; and

(b) the Chief Engineer shall have certified that such pump is constructed in accordance with these Regulations.

Construction and capacity of fixed pumps

3. (1) Fixed-supply pumps and the storage tank to be used in connection therewith shall be constructed of iron, steel or concrete of a design approved by the Chief Engineer and shall be fitted with hoses and couplings in good condition and without leaks. The air inlet shall be so arranged that the blast or explosion of any flame which may issue therefrom shall not impinge upon any part of the pump or tank or upon any inflammable substance.

(2) The storage tank in connection with any fixed-supply pump shall be of a capacity not exceeding 1,000 imperial gallons and shall be embedded in such a way that the top thereof is at no part thereof above 2 feet of the level of the surrounding ground, but, where the capacity of the storage tank does not exceed 100 imperial gallons, such tank may be placed in any building in the construction of which no inflammable material is used and which is approved by the Chief Engineer.

Construction and storage of moveable supply pumps

4. Moveable supply pumps, the tanks of which shall not exceed a capacity of 100 imperial gallons, shall be constructed of iron or steel of a design approved by the Chief Engineer and shall be fitted with hoses and couplings in good condition and without leaks. The air inlet shall be so arranged that the blast or explosion of any flame which may issue therefrom shall not impinge upon any part of the pump or tank or upon any inflammable substance.

Storage of moveable supply pumps

5. Moveable pumps when not in use shall be stored in a place approved by the Chief Engineer.

© Government of Anguilla
Copying/unauthorised distribution strictly prohibited
Printed by Authority by
The Regional Law Revision Centre Inc
www.lawrevision.ai

Use of moveable supply pumps

6. Moveable pumps may be placed only in—

(a) such position on the pavement or sidewalk that they may be clearly seen by the public and by the person in charge thereof; and

(b) such place or places as shall be approved by the Commissioner of Police.

Form of licences

7. (1) A licence to store petroleum in a fixed pump shall be in the form set out in the Schedule.

(2) A licence to store petroleum in a moveable pump other than a fixed pump shall be in the form set out in the Schedule.

Fees

8. The fee for any licence granted under these Regulations shall be as follows—

(a) for every licence to store petroleum in a fixed pump	$500 per annum or any part thereof
(b) for every licence to store petroleum in a moveable pump.....	$100 per annum or any part thereof.

Citation

9. These Regulations may be cited as the Erection and Construction of Pumps for Petroleum Storage Regulations, Revised Regulations of Anguilla, P40-2.

_____

© Government of Anguilla
Copying/unauthorised distribution strictly prohibited
Printed by Authority by
The Regional Law Revision Centre Inc
www.lawrevision.ai

SCHEDULE

(Section 7)

FORMS

FORM 1

(Section 7(1))

LICENCE TO STORE PETROLEUM IN A FIXED PUMP

Licence is hereby granted to ……of ……..…… to store ……. petroleum in accordance with the Petroleum Act, and the regulations made thereunder in a pump or pumps to be erected and maintained at …….…….. .

This licence expires on the …….. day of ..……..., 20…… .

Date …… *Comptroller of Inland Revenue*

(Act 6/2010, s. 41)

_____

FORM 2

(Section 7(2))

LICENCE TO STORE PETROLEUM IN A MOVEABLE PUMP

Licence is hereby granted to …….……. of ……. to store ……..…….. petroleum in accordance with the Petroleum Act, and the regulations made thereunder, in a moveable supply pump to be kept and maintained at …….……. .

This licence expires on the …….. day of ..……..., 20…… .

Date …… *Comptroller of Inland Revenue*

(Act 6/2010, s. 41)

_____

© Government of Anguilla
Copying/unauthorised distribution strictly prohibited
Printed by Authority by
The Regional Law Revision Centre Inc
www.lawrevision.ai