Revised Regulations of Anguilla: P40-9

PETROLEUM ACT (R.S.A. c. P40)

STORAGE OF PETROLEUM IN GARAGES AND SERVICE STATIONS REGULATIONS

Note: These Regulations are enabled under section 16 of the Petroleum Act, R.S.A. c. P40.

Quantity to be stored

1. A quantity of petroleum not exceeding 50 imperial gallons, exclusive of petroleum in the fuel tanks of motor vehicles, may be kept in a garage in accordance with these Regulations but—

(a) nothing in this section shall be deemed to prevent the storage of petroleum in a pump licensed under the Erection and Construction of Pumps for Petroleum Storage Regulations; and

(b) there may in addition be kept in a service station a quantity of petroleum other than volatile petroleum, not exceeding 100 imperial gallons.

Method of storing

2. All petroleum in garages and service stations, other than petroleum in the fuel tanks of motor vehicles, shall be kept in sound tins or drums, and such tins and drums shall be stored and kept in a non-inflammable chamber, fitted with a non-inflammable door, such chamber and door to be constructed to the satisfaction of the Chief Engineer, in a place approved by him.

Storing of tins or drums

3. All tins or drums used for containing petroleum, whether containing petroleum or not, shall be kept in the chamber provided for in section 2.

Leaking tins or drums

4. Any tin or drum in any garage or service station containing petroleum found to be in a leaking or damaged condition shall immediately be removed from the garage or service station to a place of safety in the open air, and the petroleum therein contained transferred immediately to a sound tin or drum.

Provision of sand or extinguisher

5. In every garage or service station in which petroleum is stored, otherwise than in the fuel tanks of motor vehicles, and in licensed supply pumps, there shall be maintained to the satisfaction of the Comptroller of Inland Revenue an adequate quantity of sand in suitable receptacles to be used in case of fire or some efficient type of foam extinguisher.

(Act 6/2010, s. 41)

Citation

6. These Regulations may be cited as the Storage of Petroleum in Garages and Service Stations Regulations, Revised Regulations of Anguilla, P40-9.

© Government of Anguilla
Copying/unauthorised distribution strictly prohibited
Printed by Authority by
The Regional Law Revision Centre Inc
www.lawrevision.ai